

[logo of ITB ®, or Building Research Institute]
Building Research Institute
Research | Development | Accredited Group of Laboratories |
Notified Body No. 1488 | Member of EOTA | Certified Management Systems ISO 9001, ISO 27001

REACTION TO FIRE CLASSIFICATION
as regards degree of flammability of elastic materials
00934/19/ZooNZP

Customer: TUPLEX Sp. z o.o.
ul. Księcia Ziemowita 19
03-778 Warsaw

Contract No.: 00934/19/ZooNZP

Subject of classification: Tuprint fabric.
It is a PVC-coated polyester fabric.
Type: frontlit, backlit and blackout fabric.
Weight: 440 ÷ 650 g/m².

Reaction to fire classification: The product is classified as **non-flammable**.

Basis of classification: UA GS VII. 16/2002, PN-EN ISO 6940 and PN-EN ISO 6941.
Test of degree of flammability of elastic materials.
Test Report No. LZP01-00934/19/ZooNZP and LZP02-00934/19/ZooNZP

Date of expiry: 26 February 2022

Enclosures: -

Date: 26 February 2019

Drawn up by: Mariusz Żołnik

[stamp]
Acting Head of the Fire Research Department
Bartłomiej Papis, PhD, Eng.
[two illegible signatures]

This classification may only be reproduced by the Customer in its entirety together with enclosures, without comments, abbreviations or changes.

00-611 Warsaw | ul. Filtrowa 1 | phone 22 825 04 71 | fax 22 825 52 86 | Entry No. KRS 0000158785 |
Statistical No. REGON 000063650 | Tax ID NIP 525 000 93 58 | www.itb.pl | instytut@itb.pl

END OF THE TRANSLATION

This is to certify that the foregoing is a true translation of the copy of the document in the Polish language; in witness whereof, I have subscribed my name and affixed my seal of office hereto.
Izabela Mazur, sworn translator of the English language entered in the list of sworn translators kept by the Minister of Justice of Poland; Entry No. TP/1885/06.
Records of Translations No. 240/2019
Ruda Śląska, Poland. 11 March 2019lo.

